

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7135-0065:172

Page 1 of 1

CATEGORY: Audible Signal Devices

LISTEE: Faraday, 805 S. Maumee St., Tecumseh MI 49286
Contact: Steve A. Blohm (517) 423-2111

DESIGN: Models 2830 and 2831 synchronizable electronic horns and Model 2834 synchronizable electronic horn with selectable synchronizable strobe. For synchronized operation, these devices must be used with Model 5405 or 5406 sync control module (CSFM Listing No. 7300-0065:160), a RSE-3000 notification appliance extender panel (CSFM Listing No. 7300-0065:170) or any other separately listed source of the Faraday Synchronization protocol. Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: 20-31 VDC
Selectable Candela: 15cd, 30cd, 75cd or 110cd

INSTALLATION: In accordance with the listee's printed installation instructions, NFPA 72, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as audible and audible/visual devices for use with separately listed compatible fire alarm control units. For indoor use only.

Units can generate a distinctive three-pulse Temporal Pattern Fire Alarm Evacuation Signal (for total evacuation) in accordance with NFPA 72, 1996 Edition. Refer to manufacturer's Installation Manual for details.

04-28-2002 BH



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 19, 2002**

*Listing Expires **June 30, 2003***

Authorized By: **DIANE K. AREND**, Senior Deputy
Program Manager